

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

August 17, 2012

HELLENBRAND INCORPORATED JILL MCDONALD 404 MORAVIAN VALLEY ROAD WAUNAKEE WI 53597

WATER TREATMENT DEVICE - POE SOFTENER Re: Description:

Manufacturer: HELLENBRAND INCORPORATED

Product Name: E3, H-100 AND PROMATE SERIES WATER SOFTENERS

Model Number(s): E3-024, E3-024-948, E3-032, E3-032-10, E3-032-1054, E3-048, E3-048-1354, E3-

064, E3-064-1465, H100-24ED, H100-32ED, H100-32-10ED, H100-48ED, H100-64ED, H100-96ED, H100-128ED, H100-160ED, H125-32-10, H125-48, H125-64, H125-96, H125-128, H125-160, H125-192, PM1-24ED, PM1-32ED, PM1-32-10ED, PM1-48ED, PM1-64ED, PM1-96ED, PM1-128ED, PM1-160ED, PM5-024, PM5-024RD, PM5-032, PM5-032RD, PM5-032-10, PM5-032-10RD, PM5-048, PM5-

048RD, PM5-064, PM5-064RD, PM5-096, PM5-096RD,

PM5-128, PM5-128RD, PM5-160, PM5-160RD, PM5-192, PM5-196RD,

PM6-024, PM6-032, PM6-032-10, PM6-048, PM6-064, PM6-096, PM6-160 AND

PM6-192

Product File No: 20120275

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This approval supersedes the approval issued on September 8, 2010 under product file number 20090235.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made. then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

SBD-10564-E (N.10/97) File Ref: 12027501.DOC Hellenbrand Incorporated August 17, 2012 Page 2 of 3

Product File No.: 20120275

## WATER SOFTENING CAPABILITIES PRODUCT FILE NUMBER 20120275 TABLE 1 OF 1

TABLE 1 OF 1									
Model Numbers									Flow Rate vs.
ProMate Series				ing 2		ing 3		ing 4	pressure loss
Demand Initiated Regeneration	Grains	Pounds	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
E <sup>3</sup> -024	17,200	4.5	19,980	6.0	21,040	7.5	24,230	11.3	9.8 @ 10.0
E <sup>3</sup> -032	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
E <sup>3</sup> -032-10	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	11.3 @ 10.0
E <sup>3</sup> -048	34,400	9.0	39,970	12.0	42,090	15.0	48,460	22.5	10.5 @ 10.0
E <sup>3</sup> -064	45,870	12.0	53,300	16.0	56,120	20.0	64,620	30.0	14.2 @ 10.0
E <sup>3</sup> -024-948 <sup>Δ</sup>	17,200	4.5	19,980	6.0	21,040	7.5	24,230	11.3	9.8 @ 10.0
E <sup>3</sup> -032-1054 <sup>Δ</sup>	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
E <sup>3</sup> -048-1354 <sup>Δ</sup>	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.5 @ 10.0
E <sup>3</sup> -064-1465 <sup>Δ</sup>	34,400	9.0	39,970	12.0	42,090	15.0	48,460	22.5	14.2 @ 10.0
H-100-24ED	17,200	4.5	19,980	6.0	21,040	7.5	24,230	11.3	9.8 @ 10.0
H-100-32ED H-100-32-10ED	22,930 22,930	6.0	26,650 26,650	8.0 8.0	28,060	10.0	32,310	15.0 15.0	10.1 @ 10.0 11.3 @ 10.0
H-100-32-10ED	34,400	6.0 9.0	39,970	12.0	28,060 42,090	10.0 15.0	32,310 48,460	22.5	10.5 @ 10.0
H-100-48ED	45,870	12.0	53,300	16.0	56,120	20.0	64,620	30.0	14.2 @ 10.0
H-100-96ED	68,810	18.0	79,950	24.0	84,180	30.0	96,930	45.0	14.4 @ 10.0
H-100-128ED	91,750	24.0	106,600	32.0	112,240	40.0	129,240	60.0	15.1 @ 10.0
H-100-160ED	114,690	30.0	133,250	40.0	140,300	50.0	161,550	75.0	17.3 @ 10.0
H125-32-10	19,000	6.0	28,000	10.0	32,000	15.0	-	-	22.0 @ 15.0
H125-48	28,500	9.0	42,000	15.0	48,000	22.5	_	_	19.0 @ 15.0
H125-64	38,000	12.0	56,000	20.0	64,000	30.0	_	_	25.0 @ 15.0
H125-96	57,000	18.0	84,000	30.0	96,000	45.0	-	_	24.0 @ 15.0
H125-128	76,000	24.0	112,000	40.0	128,000	60.0	-	_	25.0 @ 15.0
H125-160	95,000	30.0	140,000	50.0	160,000	75.0	-	-	27.0 @ 15.0
H125-192	114,000	36.0	168,000	60.0	192,000	90.0	-	-	26.0 @ 15.0
PM1-24ED	17,200	4.5	19,980	6.0	21,040	7.5	24,230	11.3	9.8 @ 10.0
PM1-32ED	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
PM1-32-10ED	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	11.3 @ 10.0
PM1-48ED	34,400	9.0	39,970	12.0	42,090	15.0	48,460	22.5	10.5 @ 10.0
PM1-64ED	45,870	12.0	53,300	16.0	56,120	20.0	64,620	30.0	14.2 @ 10.0
PM1-96ED	68,810	18.0	79,950	24.0	84,180	30.0	96,930	45.0	14.4 @ 10.0
PM1-128ED	91,750	24.0	106,600	32.0	112,240	40.0	129,240	60.0	15.1 @ 10.0
PM1-160ED	114,690	30.0	133,250	40.0	140,300	50.0	161,550	75.0	17.3 @ 10.0
PM5-024	17,200	4.5	19,980	6.0	21,040	7.5	24,230	11.3	9.8 @ 10.0
PM5-024RD	17,200	4.5	19,980	6.0	21,040	7.5	24,230	11.3	9.8 @ 10.0
PM5-032	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
PM5-032RD	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
PM5-032-10	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
PM5-032-10RD	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
PM5-048	34,400	9.0	39,970	12.0	42,090	15.0	48,460	22.5	10.5 @ 10.0
PM5-048RD	34,400	9.0	39,970	12.0	42,090	15.0	48,460	22.5	10.5 @ 10.0
PM5-064	45,870	12.0	53,300	16.0	56,120	20.0	64,620	30.0	14.2 @ 10.0
PM5-064RD PM5-096	45,870 68,810	12.0 18.0	53,300 79,950	16.0 24.0	56,120 84,180	20.0 30.0	64,620 96,930	30.0 45.0	14.2 @ 10.0 14.4 @ 10.0
PM5-096RD	68,810	18.0	79,950	24.0	84,180	30.0		45.0	14.4 @ 10.0
PM5-128	91,750	24.0	106,600	32.0	112,240	40.0	96,930 129,240	60.0	15.1 @ 10.0
PM5-128RD	91,750	24.0	106,600	32.0	112,240	40.0	129,240	60.0	15.1 @ 10.0
PM5-160	114,690	30.0	133,250	40.0	140,300	50.0	161,550	75.0	17.3 @ 10.0
PM5-160RD	114,690	30.0	133,250	40.0	140,300	50.0	161,550	75.0	17.3 @ 10.0
PM5-192	137,620	36.0	159,900	48.0	168,360	60.0	193,860	90.0	17.8 @ 10.0
PM5-192RD	137,620	36.0	159,900	48.0	168,360	60.0	193,860	90.0	17.8 @ 10.0
PM6-024	17,200	4.5	19,980	6.0	21,040	7.5	24,230	11.3	9.8 @ 10.0
PM6-032	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
PM6-032-10	22,930	6.0	26,650	8.0	28,060	10.0	32,310	15.0	10.1 @ 10.0
PM6-048	34,400	9.0	39,970	12.0	42,090	15.0	48,460	22.5	10.5 @ 10.0
PM6-064	45,870	12.0	53,300	16.0	56,120	20.0	64,620	30.0	14.2 @ 10.0
PM6-096	68,810	18.0	79,950	24.0	84,180	30.0	96,930	45.0	14.4 @ 10.0
PM6-128	91,750	24.0	106,600	32.0	112,240	40.0	129,240	60.0	15.1 @ 10.0
PM6-160	114,690	30.0	133,250	40.0	140,300	50.0	161,550	75.0	17.3 @ 10.0
PM6-192	137,620	36.0	159,900	48.0	168,360	60.0	193,860	90.0	17.8 @ 10.0
									_

<sup>\* =</sup> The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with NSF Standard 44.

Hellenbrand Incorporated August 17, 2012 Page 3 of 3 Product File No.: 20120275

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant
Safety and Buildings Division
Department of Safety and Professional Services
(608) 267-1401 Phone
(608) 267-9566 Fax
glen.schlueter@wi.gov Email
7:30AM - 4:30PM CT Work Hours

GWS:gws